

**Steven Goulden, Senior Counsel  
Code Development Unit  
Bureau of Legal Affairs  
New York City Fire Department  
9 MetroTech Center, Room 4W-6  
Brooklyn, NY 11201**

**RE: Proposed Rule, 3 RCNY § 309-01, Uncertified Storage Batteries for Powered  
Mobility Devices**

**October 1, 2025**

Dear Mr. Goulden:

We appreciate the opportunity to provide comments on this proposed rulemaking for uncertified storage batteries for powered mobility devices. As reflected in Table 1 of this notice, fires caused by uncertified storage batteries continue to pose a serious threat to public safety in New York City. We strongly support FDNY's efforts to mitigate these risks through the proposed ban on the storage, handling, use, charging, transport, sale, or possession of uncertified storage batteries. The recommendations outlined below are offered to support the clarity and effective implementation of the proposed rule. Specifically, FDNY could consider aligning the language of the proposed § 309-01 of the Rules of the City of New York City with § 20-610 of the Administrative Code of New York City. Further, to promote consistency and safety, FDNY could also consider measures to better define the appropriate compliance pathway for the storage batteries and battery-powered mobility devices.

UL Solutions is a leading global safety science company, committed to the mission of working for a safer world. Since 1985, our company has performed testing and certification for lithium-ion batteries and the products they power. Our knowledge of these batteries and the electrical systems they power have been integral to the development of UL 2271 in 2013, UL 2272 in 2016, UL 2849 in 2020. In addition, as a global testing, inspection, and certification (TIC) company, we have deep understanding and expertise in product compliance and market access requirements.

We commend FDNY's continued recognition of the role of standards in reducing fire and electrical safety risks. As the American National Standards for these products, the UL standards identified in the proposed rule reflect the consensus of a balanced group of technical experts for a reliable and consistent approach to mitigating the safety hazards of

lithium-ion batteries used in the electrical systems of micromobility devices sold in the U.S. Some jurisdictions with micromobility safety laws or regulations allow e-bikes to conform to EN 15194, a European e-bike standard, rather than UL 2849. The UL and EN standards were developed to address the needs of different markets and are not harmonized. The European standard covers electrically power assisted cycles (EPAC) with a top speed of 25 km/h (15.5 mph) and a maximum continuous rated power of 250 W. UL 2849, by contrast, covers EPAC and non-pedal assist e-bikes and addresses speed (and maximum power) by reference to the country of sale. Under federal regulation 16 CFR § 1512, e-bikes sold in the U.S. may operate at speeds up to 20 mph, with a maximum power of 750 W. Because e-bikes with motors over 250 W are not covered by EN 15194, it is not suitable for the U.S. market where higher power levels are the norm. We strongly recommend continuing to apply the standards developed by a balanced group of stakeholders<sup>1</sup> that reflect the powered mobility device market in the U.S. rather than Europe.

We also agree with the proposal to ban uncertified storage batteries,<sup>2</sup> and to extend that ban to include storage batteries that are component parts of uncertified micromobility devices, specifically e-scooters and e-bikes that are not certified to UL 2272 or UL 2849, respectively. However, we respectfully suggest that FDNY consider clarifying the language in § 309-01 to more closely align with Local Law 39 and § 20-610 of the Administrative Code. Currently, there is inconsistency between the definition of “powered mobility devices” within the New York City Fire Code<sup>3</sup> and the same term in the New York City Administrative Code.<sup>4</sup> While the Fire Code includes “motorized bicycles” within the term “powered mobility device,” the Administrative Code does not include those devices within the term. Instead, the Administrative Code refers to “powered bicycles”<sup>5</sup> and uses separate provisions to regulate the those devices.<sup>6</sup> The proposed rule appears to include powered bicycles within the larger category of powered mobility devices. To avoid confusion and ensure clear enforcement, we recommend revising the rule to explicitly include both categories.

For example, the following revision to § 309-01(b)(1) could help clarify the scope ([suggested revision](#)):

---

<sup>1</sup> UL standards are developed by UL Standards and Engagement (ULSE) following a process accredited by the American National Standards Institute (ANSI). For more information about ULSE standards development and the ANSI process, see [Policies and Procedures | UL Standards & Engagement](#).

<sup>2</sup> For micromobility applications, a storage battery may also be referred to as a light electric vehicle battery or a traction battery.

<sup>3</sup> *New York City Fire Code* § FC 202 (2022). Defines “Powered Mobility Devices” as “Motorized bicycles, motorized scooters and other personal mobility devices powered by a lithium-ion or other storage battery. The term does not include motor vehicles or motorcycles or other mobility devices that must be registered with the New York State Department of Motor Vehicles.”

<sup>4</sup> *New York City Administrative Code* § 20-609 (2025). Defines “powered mobility device” as “an electric scooter as defined in section 114-e of the vehicle and traffic law or successor provision or other personal mobility device powered by a lithium-ion or other storage battery. The term does not include powered bicycles, wheelchairs or other mobility devices designed for use by persons with disabilities, or any vehicle that is capable of being registered with the New York State Department of Motor Vehicles.”

<sup>5</sup> *New York City Administrative Code* § 20-609 (2025). Defines “powered bicycle” as “a bicycle with electric assist as defined in section 102-c of the vehicle and traffic law.”

<sup>6</sup> See N.Y.C. Admin. Code § 20-610(a)-(b) (2025).

(b) General Provisions.

(1) Prohibition. It shall be unlawful to store, handle, use, charge, transport, sell, or possess a storage battery for a powered mobility device or a powered bicycle unless such storage battery:

(A) Has been certified by an accredited testing laboratory for compliance with Underwriters Laboratories (UL) standard 2271; or

(B) Is a component part of a powered mobility device that has been certified by an accredited testing laboratory for compliance with UL 2272 or is a component part of a powered bicycle that has been certified by an accredited testing laboratory to UL 2849; or

(C) Has been certified, or is a component part of a powered mobility device or powered bicycle that has been certified, by an accredited testing laboratory for compliance with a safety standard that the Department of Consumer and Worker Protection, in consultation with the Department, has established by rule pursuant to section 20-610 of the Administrative Code.

In addition to clarifying that the regulation applies to all micromobility products, FDNY should consider providing clearer guidance on how regulated parties can comply. Both Local Law 39 and the proposed § 309-01 require micromobility products' electrical systems to be "certified by an accredited testing laboratory."<sup>7,8</sup> However, under the Department of Consumer and Worker Protection (DCWP) regulations, an accredited testing laboratory may be accredited to ISO/IEC 17025, ISO/IEC 17065, or recognized as an Occupational Safety and Health Administration (OSHA) Nationally Recognized Testing Laboratory (NRTL).<sup>9</sup> These are different designations:

- ISO/IEC 17025 accreditation assesses a lab's technical capabilities to generate reliable test data. Accreditors typically assess labs to a defined scope of accreditation.<sup>10</sup>
- ISO/IEC 17065 accreditation assesses a certification body's policies and procedures to "ensure that [it] operate[s] certification schemes in a competent,

---

<sup>7</sup> E.g., *New York City Administrative Code* § 20-610(a). Stating "It shall be unlawful to distribute, sell, [etc.] a powered bicycle, powered mobility device, or storage battery for such devices unless such bicycle, device, or battery has been certified by an accredited testing laboratory for compliance with applicable safety standards . . .".

<sup>8</sup> E.g., *FDNY Proposed Rule* § 309-01(b)(A). Prohibiting sale (etc.) of storage batteries unless "certified by an accredited testing laboratory for compliance with Underwriters Laboratories (UL) standard 2271".

<sup>9</sup> *Rules of the City of New York*, Title 6, Chapter 4, Subchapter L, § 4-150. Accessed September 24, 2025. <https://www.nyc.gov/site/law/public-resources/laws-of-the-city-of-new-york.page>.

<sup>10</sup> See e.g., UL 2271, *Standard for Batteries for Use in Light Electric Vehicle (LEV) Applications*, p. 11. Identifying ICS Codes 29.220 (Electrical energy storage systems) and 43.120 (Electric road vehicles) (Underwriters Laboratories Inc., 2023).

consistent and impartial manner, thereby facilitating . . . the acceptance of certified products . . .”<sup>11,12</sup>

- NRTLs are recognized by OSHA for meeting requirements that encompass both ISO standards and additional oversight measures.<sup>13</sup>

Because § 4-150 of the Rules of the City of New York refer to each of these in the definition of “accredited testing laboratory,” there are three paths for compliance, each with a different level of rigor. ISO/IEC 17025 alone is insufficient for certification<sup>14</sup> since it does not assess product construction or require production surveillance.<sup>15,16</sup> ISO/IEC 17065 requires surveillance programs,<sup>17</sup> but the specifics vary by certification scheme. In contrast, the NRTL program mandates factory surveillance two to four times annually.<sup>18</sup> The surveillance process checks that the manufacturer has not made changes to the product that affect the issued safety certification.

While consistency across city agencies is important, the current compliance options under DCWP regulations vary in rigor and may lead to uneven enforcement. We urge FDNY, in coordination with DCWP, to strengthen and clarify compliance requirements. The NRTL framework offers a comprehensive review process, covering both the testing (ISO/IEC 17025) and certification (ISO/IEC 17065) components. The program also benefits from federal oversight which supports consistent and reliable safety outcomes across testing and certification bodies.

We commend New York City’s leadership in addressing micromobility product safety and FDNY’s steadfast focus on life safety. Lithium-ion batteries under thermal runaway conditions can cause deflagrations, intense and very fast-moving fires, and produce toxic gases that are hazardous for civilians and firefighters alike. Therefore, it is critical that lithium-ion batteries are certified (listed and labeled by definition) to applicable safety standards, like UL 2271, and only be used in product electrical systems that conform to safety standards, like UL 2272 and UL 2849. We appreciate the opportunity to provide these comments and are available to answer any further questions. Should you have such questions, please contact Bruce Johnson, Regulatory Services Manager

---

<sup>11</sup> *ISO/IEC 17065:2012, Conformity Assessment—Requirements for Bodies Certifying Products, Processes and Services*. Geneva: International Organization for Standardization, 2012, p. v.

<sup>12</sup> Among other topics, ISO/IEC 17065 includes impartiality management policies, organizational structure, and product surveillance, as well as the procedures and requirements for product evaluations for product certifications.

<sup>13</sup> See *Occupational Safety and Health Administration. NRTL Program Policies, Procedures, and Guidelines*. OSHA Directive CPL 01-00-004. Washington, DC: U.S. Department of Labor, October 1, 2019. <https://www.osha.gov/dts/otpca/nrtl/nrtl-dir.html>. Detailing the NRTL program requirements.

<sup>14</sup> Certification can also be referred to as “listed.” *New York City Fire Code* § FC 202 (2022). Defines “Listed” as “A material, device, equipment or system included on a list published by a nationally recognized testing laboratory or other approved organization performing product evaluations that maintains periodic inspection of production of such listed material, device, equipment or system, and whose listing indicates compliance with nationally recognized standards and designates suitable usage.”

<sup>15</sup> E.g., UL 2849 construction requirements, like a safety analysis of the product’s circuitry and a review of the materials used in product construction. An assessment of whether the product conforms to the standard should be performed by a qualified engineer.

<sup>16</sup> See Carnahan, Lisa, and Amy Phelps. *ABC’s of Conformity Assessment*. NIST Special Publication 2000-01. Gaithersburg, MD: National Institute of Standards and Technology, September 2018, p. 12-14. <https://doi.org/10.6028/NIST.SP.2000-01>. Provides an overview of certification, including the evaluation of evidence of conformity, like test reports produced by ISO/IEC 17025 accredited laboratories.

<sup>17</sup> ISO/IEC 17065:2012, *Conformity Assessment—Requirements for Bodies Certifying Products, Processes and Services*, § 7.9.3.

<sup>18</sup> *NRTL Program Policies, Procedures, and Guidelines*, OSHA Directive CPL 01-00-004 (October 1, 2019), Annex B-14.

(bruce.johnson@ul.com), or Meghan Housewright, Government Affairs Lead  
(meghan.housewright@ul.com).

Sincerely,

Bruce Johnson  
Regulatory Services Manager  
UL Solutions